

3.5 OTHER CONSIDERATIONS FOR THE FIRE RECONSTRUCTION

In reconstructing the fires of September 11, 2001, there were additional features that were considered:

- The aircraft damaged the risers, and no water was available for the sprinkler or standpipe systems (NIST NCSTAR 1-4).
- There was no action by building occupants that affected the course of the fires other than the breaking of windows on the fire floors (NIST NCSTAR 1-7).

3.6 REFERENCES

- Alpert, R.L. 2002. Ceiling Jet Flows, in DiNenno, ed., *The SFPE Handbook of Fire Protection Engineering*, NFPA International, Quincy, MA, p. 2-24.
- ASTM International. 2000. Standard Test Methods for Fire Tests of Building Construction and Materials, vol. 4.07. ASTM E 119-00a, *Annual Book of ASTM Standards*, West Conshohocken, PA.
- ASTM International. 2003. Standard Test Method for Surface Burning Characteristics of Building Materials, vol. 4.07. ASTM E 84-03, *Annual Book of ASTM Standards*, West Conshohocken, PA.
- ASTM International. 2003a. Standard Test Method for Heat and Visible Smoke Release Rates for Materials and Products Using an Oxygen Consumption Calorimeter, vol. 4.07. ASTM E1354-03, *Annual Book of ASTM Standards*, West Conshohocken, PA.
- Barry, D.T. 2003a. Condon & Forsyth LLP, New York, NY, memorandum to M.R. Rubin and M. Lieberman, National Institute of Standards and Technology, Gaithersburg, MD, October 31.
- Caro, T.C., and J.A. Milke. 1996. A Survey of Fuel Loads in Contemporary Office Buildings, NIST-GCR-96-697, National Institute of Standards and Technology, Gaithersburg, MD, September.
- Culver, C.G. 1978. Characteristics of Fire Loads in Office Buildings, *Fire Technology*, vol. 14, pp. 51-61.
- Drysdale, D.D. 2002. Thermochemistry, in DiNenno, ed., *The SFPE Handbook of Fire Protection Engineering*, NFPA International, Quincy, MA, p. 1-93.
- Fleck, D. 2003. Arenson Office Furnishings, NY, NY, personal communication to T.J. Ohlemiller, National Institute of Standards and Technology, Gaithersburg, MD.
- Fritz, T.A., and P.A. Hough. 2002. Armstrong World Industries, Lancaster, PA, personal communication to R.G. Gann, National Institute of Standards and Technology, Gaithersburg, MD.
- Huggett, C. 1980. Estimation of rate of heat release by means of oxygen-consumption measurements. *Fire and Materials*, vol. 4, pp. 61-65.
- Madrzykowski, D. 1996. Office Workstation Heat Release Rate Study: Full-scale vs. Bench-scale. Proceedings of Interflam '96, Interscience Communications, Ltd., London, pp. 47-55.